

The logo for IRSN, featuring the letters 'IRSN' in a bold, sans-serif font. The 'I', 'R', and 'S' are red, while the 'N' is blue.

INSTITUT
DE RADIOPROTECTION
ET DE SÛRETÉ NUCLÉAIRE

Enhancing nuclear safety

Annual report of the French industrial radiography incidents declared in 2014

16th European ALARA
Network Workshop

Bern - March 2016

PRP-HOM/SER

Authors : Anne Cordelle
Ben-Mekki AYADI

© IRSN

IRSN activities related to industrial radiography

Surveillance of operators' exposure to ionizing radiation



Dimensioning calculation (shielded enclosures)



National register for radioactive sources (Hass) and incidents database



Training and examination



Topic of the presentation : a feedback

➤ Significant radiological events in 2014 in France for industrial radiography activities

➤ Objective

Identify main causes of incidents



Analyse their evolution in time




Report of radiography incidents in France in 2014

➤ 17 significant events related to radiography



Report of radiography incidents in France in 2014

➤ 17 significant events - Where ?



Report of radiography incidents in France in 2014

➤ 17 significant events - INES Scale



Report of radiography incidents in France in 2014

➤ 17 significant events - The cause



Loss of control of
radioactive source



9 events



Non-compliance with
regulatory operational
provisions



8 events

Equipment used in France

➤ Gam80/120



Equipment most widely used in France

600 devices in France, 90 % Gam80/120

Equipment in France

➤ Radioactive source

Ir192, Se75 (1-3 TBq)




Source holder



Exposure container


Equipment in France

➤ Shielded position





Equipment in France

➤ Drive cable connection




Equipment in France

➤ Guide tube connection



Equipment in France

➤ Indicators



→ Device unlocked



← Shutter control removed



→ Source holder broken

Report of radiography incidents in France in 2014

➤ 17 significant events



Loss of control of
radioactive source



9 events



Non-compliance with
regulatory operational
provisions

8 events

Report of radiography incidents in France in 2014

➤ 17 significant events



Loss of control of
radioactive source



9 events

1. Source stuck in the equipment
2. Source no more controlled
3. Source out of the equipment

Report of radiography incidents in France in 2014

➤ 17 significant events



Loss of control of
radioactive source



9 events

1. Source stuck in the equipment → 3 events

2. Source no more controlled

3. Source out of the equipment

Report of radiography incidents in France in 2014

➤ Source becoming stuck in the equipment

	Source location	Cause	INES scale	Operator intervention	Dosimetric consequences
Event 1	Guide tube		Level 2	yes	22 mSv
Event 2	Container	Presence of an object in the container	Level 1	yes	no
Event 3	Guide tube		Level 0	no	no

Report of radiography incidents in France in 2014

➤ Event 1 - Level 2

- Site radiography work (2 operators)
- Gam80 - Ir192 - 2,62 TBq
- 5th shot : source totally stuck in the guide tube

Prohibition of intervention

- With a metal rod, the operator pushed the source into the container
 - Dose : 22 mSv (in less than a minute)


Report of radiography incidents in France in 2014

➤ 17 significant events


Loss of control of radioactive source



9 events




1. Source stuck in the equipment



3 events

2. Source no more controlled (shutter rupture)



6 events


3. Source out of the equipment

Report of radiography incidents in France in 2014

➤ Rupture of the shutter

- Old equipment
- Hard to detect the problem
- Operator alerted by different indices
- Organization of a shutter change campaign by the supplier
- Information to all radiography companies


Rupture of the shutter




Non-compliance with regulatory operational provisions



8 events




Regulatory operational provisions



Regulatory operational provisions

Which must be performed





Nuclear power plants


Markup : main failures

Default of markup

5

events

INES 0





Nuclear
power plants

Markup : main failures


- Updated plans with entire topographic constraints



- No dosimetric consequences : the markup defects were highlighted by the controls performed before each shot

➤ 5 events / 6000 shots


Organization "preparation / validation"
robust and reliable



Industrial facilities

Default of markup - an atypical event

INES 0



Shots were made without a controlled area


➔ Stakeholders could easily enter the shooting area



Discovered by an unannounced inspection authorities

➔ Fortunately no one has been exposed

Put out the importance of regular unannounced inspections




Industrial facilities

Crossing markup

INES 2

Believing the shooting ended, the operator entered to remove the film while the radioactive source was not in the locked position.



Without survey meter



Despite the active dosimeter alarm



Regardless of the sentinel surveillance tag



Lack of communication


1
minutes



5,3 mSv

Conclusion

- 17 events divided into two typology :



- 2 events with dosimetric consequences (22 and 5 mSv)
- Few events compared with the number of annual shooting
- Human and organizational factors mainly involved
- Importance of checks before shooting and unannounced inspections

Thank you for your attention

Questions

